



PRODUCT TESTING SERVICES

100 Clemson Research Blvd. Anderson, SC 29625 Tel (864) 646-TILE Fax (864) 646-2821

TCNA TEST REPORT NUMBER: TCNA-280-10

PAGE: 1 OF 1


TEST REQUESTED BY: Quarry Tile Co.
Attn: Dirk Elliot
6328 E. Utah Ave
Spokane, WA 99212

TEST SUBJECT MATERIAL: Identified by client as: Quarry Tile Natural Hues

TEST DATE: 8/17/10

TEST PROCEDURE: Mohs Scratch Hardness
-Three whole tiles were tested.

TEST RESULTS: The Mohs Scratch Hardness was determined to be: 7. (The Mohs Scratch Hardness Scale runs from 1-talc to 10-diamond.)


Katelyn Simpson
Laboratory Manager

8/24/10
Date